



A Geosyntec Company

**Addendum #2  
Request for Bids (RFB) 2023-05  
Isle of Palms Marina – Public Dock and Intracoastal Dock Improvements  
November 15, 2023**

This addendum is intended to provide further clarification to the Bid Documents for this project, dated October 19, 2023.

General Information

- The deadline for questions on this bid has been extended until November 18, 2023 at 6pm local time.
- The bid due date and time remains the same: November 21, 2023 at 2pm local time. Please refer to bid documents for submittal requirements.
- Bidders are strongly encouraged but not required to submit pricing for all alternates indicated on the bid form.
- Regarding Alternate 5, Contractor shall consider need for potential additional stringers/blocking to accommodate edge boards and include such in pricing for this alternate.
- Regarding Bid Alternate 6, please note the following:
  - This alternate is intended to focus on the fixed pier portion of the Public Dock
  - The screws for decking shall remain stainless steel in any case
  - The lag bolts for the aluminum in-fill in the handrail system (the vertical aluminum posts/pickets) may be stainless steel or HDG (properly insulated)
  - The hardware to attach the aluminum gangway to the fixed pier may be stainless steel or HDG (properly insulated)
  - The Simpson hurricane straps shall remain stainless steel, fastened with stainless steel nails
- Bidders shall note that immediately proximate to the proposed Public Dock that there is a subaqueous high voltage electrical transmission line that leads from the Isle of Palms to Goat Island. The line is understood to be adjacent to the site property line and not in the immediate footprint of the proposed fixed pier or floating dock. Bidders shall consider this in their work plan and bid. The selected contractor shall take great care to coordinate with the power company to locate and safely avoid this line.