

**CITY OF ISLE OF PALMS, SOUTH CAROLINA  
REQUEST FOR BID (RFB) 2024-12  
COUNTY PARK EMERGENCY ACCESS**

**QUESTIONS AND RESPONSES- DECEMBER 16, 2024**

**1. Should the grading include new sod installation?**

Sod is included in the planting plan, so it would be within the landscape sub-contract scope. The irrigation for turf and other planting is provided by CCPRC. This will need to be coordinated with CCPRC's irrigation installer so the irrigation is operational before sod is laid.

**2. Who will be responsible for moving the fiber optic handhole box where the new entrance goes.**

This is an AT&T line and it appears that the box will be outside of the new path, but if not the City will coordinate moving the box with AT&T.

**3. Where is the newspaper box to be relocated?**

The City will handle newspaper box relocation (it should be already relocated).

**4. Who will be responsible for controls of new gate new gates and should include conduit for these controls?**

Yes, a separate conduit for the gate electrical controls is needed.

**5. Could the existing clutter bridge be reused or modified to meet current requirements?**

No, the existing timbers are smaller than the proposed. The existing timbers have not held up.